

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Box R Waterlab
Project: X022776 AC Houghton ES Lead Study
Lab Order: 1606B49

Date: 11-Jul-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B49
NRC Sample ID: 1606B49-01A
Collection Date: 6/23/2016 9:08:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:19:34 AM

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #1
Collectors Name: SKM
Sample Location: Room 23 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000992		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B49
NRC Sample ID: 1606B49-02A
Collection Date: 6/23/2016 8:59:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:19:34 AM

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #2
Collectors Name: SKM
Sample Location: A Wing DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00594		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B49**
NRC Sample ID: **1606B49-03A**
Collection Date: **6/23/2016 9:11:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:19:34 AM**

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: **X022776 #3**
Collectors Name: **SKM**
Sample Location: **Gym DF**
Source: **City Water**

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00143		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B49
NRC Sample ID: 1606B49-04A
Collection Date: 6/23/2016 6:00:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:19:34 AM

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #4
Collectors Name: SKM
Sample Location: Cafeteria DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00294		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B49**
NRC Sample ID: **1606B49-05A**
Collection Date: **6/23/2016 8:39:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:19:34 AM**

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #5
Collectors Name: SKM
Sample Location: Room 2 Sink Low
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000438		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B49
NRC Sample ID: 1606B49-06A
Collection Date: 6/23/2016 9:02:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:19:34 AM

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #6
Collectors Name: SKM
Sample Location: #25 Custodial DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00381		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B49
NRC Sample ID: 1606B49-07A
Collection Date: 6/23/2016 9:00:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:19:34 AM

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #7
Collectors Name: SKM
Sample Location: Room 18 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00120		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B49
NRC Sample ID: 1606B49-08A
Collection Date: 6/23/2016 8:51:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:19:34 AM

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #8
Collectors Name: SKM
Sample Location: Room 16 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00373		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B49
NRC Sample ID: 1606B49-09A
Collection Date: 6/23/2016 8:40:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:19:34 AM

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #9
Collectors Name: SKM
Sample Location: Room 2 Higher Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000374		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B49**
NRC Sample ID: **1606B49-10A**
Collection Date: **6/23/2016 6:03:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:19:34 AM**

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #10
Collectors Name: SKM
Sample Location: Kitchen Triple Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00535		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B49**
NRC Sample ID: **1606B49-11A**
Collection Date: **6/23/2016 8:52:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:19:34 AM**

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #11
Collectors Name: SKM
Sample Location: Room A-15 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00250		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B49**
NRC Sample ID: **1606B49-12A**
Collection Date: **6/23/2016 8:44:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:19:34 AM**

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #12
Collectors Name: SKM
Sample Location: Room 1 Right Side DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00148		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B49
NRC Sample ID: 1606B49-13A
Collection Date: 6/23/2016 8:45:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:19:34 AM

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #13
Collectors Name: SKM
Sample Location: Before Room 1 Hall DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00863		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B49**
NRC Sample ID: **1606B49-14A**
Collection Date: **6/23/2016 9:20:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:19:34 AM**

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #14
Collectors Name: SKM
Sample Location: Teacher Lounge
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00155		0.000103	mg/L	0.020 AL	7/7/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B49
NRC Sample ID: 1606B49-15A
Collection Date: 6/23/2016 8:58:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:19:34 AM

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #15
Collectors Name: SKM
Sample Location: A12 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00502		0.000103	mg/L	0.020 AL	7/7/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B49
NRC Sample ID: 1606B49-16A
Collection Date: 6/23/2016 8:55:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:19:34 AM

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #16
Collectors Name: SKM
Sample Location: A14 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0126		0.000103	mg/L	0.020 AL	7/7/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B49**
NRC Sample ID: **1606B49-17A**
Collection Date: **6/23/2016 8:43:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:19:34 AM**

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #17
Collectors Name: SKM
Sample Location: Room 1 Left Side Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00379		0.000103	mg/L	0.020 AL	7/7/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B49**
NRC Sample ID: **1606B49-18A**
Collection Date: **6/23/2016 8:52:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:19:34 AM**

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #18
Collectors Name: SKM
Sample Location: Kitchen Pot Filling Faucet
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00172		0.000103	mg/L	0.020 AL	7/7/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B49**
NRC Sample ID: **1606B49-19A**
Collection Date: **6/23/2016 8:57:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:19:34 AM**

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #19
Collectors Name: SKM
Sample Location: Room 11 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00781		0.000103	mg/L	0.020 AL	7/7/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B49**
NRC Sample ID: **1606B49-20A**
Collection Date: **6/23/2016 9:15:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:19:34 AM**

Sample Information:

X022776 AC Houghton ES Lead Study

Client Sample ID: X022776 #20
Collectors Name: SKM
Sample Location: Outside Playground DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.000693		0.000103	mg/L	0.020 AL	7/7/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

Date: 11-Jul-16

CLIENT: Box R Waterlab
Work Order: 1606B49
Project: X022776 AC Houghton ES Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	MB-35674	SampType:	MBLK	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88231
Client ID:	ZZZZ	Batch ID:	35674	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/5/2016	SeqNo:	1319756
Analyte		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		ND	0.000103								

Sample ID	MB-35675	SampType:	MBLK	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88287
Client ID:	ZZZZ	Batch ID:	35675	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/7/2016	SeqNo:	1321084
Analyte		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		ND	0.000103								

Sample ID	LCS-35674	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88231
Client ID:	ZZZZ	Batch ID:	35674	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/5/2016	SeqNo:	1319757
Analyte		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09432	0.000104	0.1	0	94.3	85	115			

Sample ID	LCS-35675	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88287
Client ID:	ZZZZ	Batch ID:	35675	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/7/2016	SeqNo:	1321085
Analyte		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09722	0.000104	0.1	0	97.2	85	115			

Sample ID	1606B49-13AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88231
Client ID:	X022776 #13	Batch ID:	35674	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/5/2016	SeqNo:	1319780
Analyte		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.1086	0.000104	0.1	0.008634	99.9	70	130			

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

Neilson Research Corporation

Date: 11-Jul-16

CLIENT: Box R Waterlab
 Work Order: 1606B49

ANALYTICAL QC SUMMARY REPORT

Project: X022776 AC Houghton ES Lead Study

TestCode: ICPMS_200.8_SCHOOL

Sample ID	1606B74-03AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88287								
Client ID:	ZZZZ	Batch ID:	35675	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/7/2016	SeqNo:	1321109								
Analyte	Lead	Result	0.09838	MRL	0.000104	SPK value	0.1	%REC	93.5	LowLimit	70	HighLimit	130	RPD Ref Val		%RPD		RPDLimit	Qual

Sample ID	1606B49-13AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88231								
Client ID:	X022776 #13	Batch ID:	35674	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/5/2016	SeqNo:	1319781								
Analyte	Lead	Result	0.1099	MRL	0.000104	SPK value	0.1	%REC	101	LowLimit	70	HighLimit	130	RPD Ref Val	0.1086	%RPD	1.24	RPDLimit	20

Sample ID	1606B74-03AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88287								
Client ID:	ZZZZ	Batch ID:	35675	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/7/2016	SeqNo:	1321110								
Analyte	Lead	Result	0.1001	MRL	0.000104	SPK value	0.1	%REC	95.2	LowLimit	70	HighLimit	130	RPD Ref Val	0.09838	%RPD	1.71	RPDLimit	20

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits