

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Box R Waterlab
Project: X022778 Irrigon HS Lead Study
Lab Order: 1606B46

Date: 11-Jul-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B46**
NRC Sample ID: **1606B46-01A**
Collection Date: **6/22/2016 6:30:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:17:22 AM**

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #1
Collectors Name: SKM
Sample Location: Main Sink Kitchen
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00128		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B46
NRC Sample ID: 1606B46-02A
Collection Date: 6/22/2016 8:50:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:17:22 AM

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #2
Collectors Name: SKM
Sample Location: Cafeteria Kitchen Hand Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.0187	CF	0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B46**
NRC Sample ID: **1606B46-03A**
Collection Date: **6/22/2016 6:30:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:17:22 AM**

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: **X022778 #3**
Collectors Name: **SKM**
Sample Location: **Kitchen Dish Wash Sink**
Source: **City Water**

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00161		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B46**
NRC Sample ID: **1606B46-04A**
Collection Date: **6/22/2016 9:06:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:17:22 AM**

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: **X022778 #4**
Collectors Name: **SKM**
Sample Location: **Staff Sink**
Source: **City Water**

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00328		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B46
NRC Sample ID: 1606B46-05A
Collection Date: 6/22/2016 10:31:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:17:22 AM

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #5
Collectors Name: SKM
Sample Location: Hallway T by Girls RR DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00238		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B46
NRC Sample ID: 1606B46-06A
Collection Date: 6/22/2016 10:29:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:17:22 AM

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #6
Collectors Name: SKM
Sample Location: Outside Cafeteria DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00103		0.0001	mg/L	0.020 AL	7/7/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B46**
NRC Sample ID: **1606B46-07A**
Collection Date: **6/22/2016 10:15:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:17:22 AM**

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #7
Collectors Name: SKM
Sample Location: Office Hallway DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00433		0.000103	mg/L	0.020 AL	7/7/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B46**
NRC Sample ID: **1606B46-08A**
Collection Date: **6/22/2016 10:30:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:17:22 AM**

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: **X022778 #8**
Collectors Name: **SKM**
Sample Location: **Main Hallway Higher DF**
Source: **City Water**

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00303		0.000103	mg/L	0.020 AL	7/7/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B46
NRC Sample ID: 1606B46-09A
Collection Date: 6/22/2016 10:25:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:17:22 AM

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #9
Collectors Name: SKM
Sample Location: PT Bldg Lower DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.000722		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B46
NRC Sample ID: 1606B46-10A
Collection Date: 6/22/2016 9:20:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:17:22 AM

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #10
Collectors Name: SKM
Sample Location: PT Bldg Higher DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.000771		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL.

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B46**
NRC Sample ID: **1606B46-11A**
Collection Date: **6/22/2016 10:02:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:17:22 AM**

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #11
Collectors Name: SKM
Sample Location: T Hallway Lower DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00355		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B46
NRC Sample ID: 1606B46-12A
Collection Date: 6/22/2016 9:15:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:17:22 AM

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #12
Collectors Name: SKM
Sample Location: Music Room Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00607		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B46
NRC Sample ID: 1606B46-13A
Collection Date: 6/22/2016 10:32:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:17:22 AM

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #13
Collectors Name: SKM
Sample Location: GRC Room Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.00178		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B46
NRC Sample ID: 1606B46-14A
Collection Date: 6/22/2016 10:31:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:17:22 AM

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #14
Collectors Name: SKM
Sample Location: Bottle Fill Dispenser
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	ND		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: 1606B46
NRC Sample ID: 1606B46-15A
Collection Date: 6/22/2016 10:28:00 AM
Received Date: 6/27/2016 12:30:00 PM
Reported Date: 7/11/2016 8:17:22 AM

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #15
Collectors Name: SKM
Sample Location: Cafeteria DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0115		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Box R Waterlab
567 NW Second Street
Prineville, OR 97754

Lab Order: **1606B46**
NRC Sample ID: **1606B46-16A**
Collection Date: **6/22/2016 9:36:00 AM**
Received Date: **6/27/2016 12:30:00 PM**
Reported Date: **7/11/2016 8:17:22 AM**

Sample Information:

X022778 Irrigon HS Lead Study

Client Sample ID: X022778 #16
Collectors Name: SKM
Sample Location: Gym Higher DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Lead	EPA 200.8	A	0.000218		0.000103	mg/L	0.020 AL	7/5/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

Date: 11-Jul-16

CLIENT: Box R Waterlab
 Work Order: 1606B46
 Project: X022778 Irrigon HS Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	MB-35673	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/2/2016	RunNo: 88212					
Client ID:	ZZZZZ	Batch ID: 35673	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/4/2016	SeqNo: 1319434					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Lead	ND	0.000103									

Sample ID	MB-35674	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/2/2016	RunNo: 88231					
Client ID:	ZZZZZ	Batch ID: 35674	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/5/2016	SeqNo: 1319756					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Lead	ND	0.000103									

Sample ID	MB-35695	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/5/2016	RunNo: 88287					
Client ID:	ZZZZZ	Batch ID: 35695	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/7/2016	SeqNo: 1321060					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Lead	ND	0.000103									

Sample ID	LCS-35673	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/2/2016	RunNo: 88212					
Client ID:	ZZZZZ	Batch ID: 35673	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/4/2016	SeqNo: 1319435					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Lead	0.09644	0.000104	0.1	0	96.4	85	115				

Sample ID	LCS-35674	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/2/2016	RunNo: 88231					
Client ID:	ZZZZZ	Batch ID: 35674	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/5/2016	SeqNo: 1319757					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Lead	0.09432	0.000104	0.1	0	94.3	85	115				

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

Neilson Research Corporation

Date: 11-Jul-16

CLIENT: Box R Waterlab
 Work Order: 1606B46

Project: X022778 Irrigon HS Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	LCS-35695	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/5/2016	RunNo:	88287
Client ID:	ZZZZ	Batch ID:	35695	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/7/2016	SeqNo:	1321061
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Lead	0.09643	0.000104	0.1	0	96.4	85	115				

Sample ID	1606B46-09AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88231
Client ID:	X022778 #9	Batch ID:	35673	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/5/2016	SeqNo:	1319752
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Lead	0.09844	0.000104	0.1	0.0007218	97.7	70	130				

Sample ID	1606B49-13AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88231
Client ID:	ZZZZ	Batch ID:	35674	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/5/2016	SeqNo:	1319780
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Lead	0.1086	0.000104	0.1	0.008634	99.9	70	130				

Sample ID	1607015-26AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/5/2016	RunNo:	88287
Client ID:	ZZZZ	Batch ID:	35695	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/7/2016	SeqNo:	1321080
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Lead	0.09294	0.000104	0.1	0.001642	91.3	70	130				

Sample ID	1606B46-09AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88231
Client ID:	X022778 #9	Batch ID:	35673	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/5/2016	SeqNo:	1319753
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Lead	0.09833	0.000104	0.1	0.0007218	97.6	70	130	0.09844	0.106		20

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

Neilson Research Corporation

Date: 11-Jul-16

CLIENT: Box R Waterlab
 Work Order: 1606B46

ANALYTICAL QC SUMMARY REPORT
 TestCode: ICPMS_200.8_SCHOOL

Project: X022778 Irrigon HS Lead Study

Sample ID	1606B49-13AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/2/2016	RunNo:	88231		
Client ID:	ZZZZZ	Batch ID:	35674	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/5/2016	SeqNo:	1319781		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Lead		0.1099		0.000104	0.1	0.008634	101	70	130	0.1086	1.24	20	

Sample ID	1607015-26AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/5/2016	RunNo:	88287		
Client ID:	ZZZZZ	Batch ID:	35695	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/7/2016	SeqNo:	1321081		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09388		0.000104	0.1	0.001642	92.2	70	130	0.09294	1.00	20	

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits