

Outside testing

LAB FEDERAL ID#:		ID00013
DATE RECEIVED:	10/14/2016	DATE REPORTED BY LAB:
		11/8/2016
COMPLIANCE SAMPLE: YES		REPLACEMENT SAMPLE: NO
SAMPLE TYPE:		
PWS #:	PWS NAME:	
	MORROW COUNTY SCHOOL DIST.	
CONTACT NAME:		CONTACT PHONE:
TABLE ROCK ANALYTICAL LAB		



Anatek Labs, Inc.

1282 Alturas Drive
Moscow, ID 83843
(208) 883-2839
FAX 882-9246
moscow@anateklabs.com

504 E. Sprague Ste. D
Spokane, WA 99202
(509) 838-3999
FAX 838-4433
spokane@anateklabs.com

www.anateklabs.com

Lead Analysis Report

Lab Sample #	Sample Location	Collection Date / Time	Analyte	Result	Method	Analysis Date	Analyst	Qualifier
161014025-001	161012H1 / HHS BASEBALL - VISITOR DUGOUT	10/12/2016 7:30 AM	Lead	0.00472	EPA 200.8	10/31/2016	HSW	
161014025-002	161012H2 / HHS BASEBALL - HOME DUGOUT	10/12/2016 7:30 AM	Lead	0.00118	EPA 200.8	10/31/2016	HSW	
161014025-003	161012H3 / TRACK FIELD - HHS	10/12/2016 7:40 AM	Lead	ND	EPA 200.8	10/31/2016	HSW	
161014025-004	161012H4 / HHS FOOTBALL FIELD	10/12/2016 7:50 AM	Lead	ND	EPA 200.8	10/31/2016	HSW	

MCL (Maximum Contaminant Level) for Lead is 0.020 mg/L.

MDL (Method Detection Limit) is 0.001 mg/L for Lead.

ND = Analyte Not Detected

All results in mg/L unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The results reported relate only to the samples indicated.

Soil/solid results are reported on a dry-weight basis unless otherwise noted.

TABLE ROCK ANALYTICAL LAB
MORROW COUNTY SCHOOL DIST.
PO BOX 100
HEPPNER, OR 97836

Authorized Signature

Todd Taruscio, Lab Manager

Comments:

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:Cert0028; NM: ID00013; NV:ID00013; OR:ID20001-002; WA:C595
Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

LAB FEDERAL ID#: ID00013	
DATE RECEIVED: 10/14/2016	DATE REPORTED BY LAB: 11/3/2016
COMPLIANCE SAMPLE: YES	REPLACEMENT SAMPLE: NO
SAMPLE TYPE:	
PWS #:	PWS NAME: MORROW COUNTY SCHOOL DIST.
CONTACT NAME: TABLE ROCK ANALYTICAL LAB	CONTACT PHONE:



Anatek Labs, Inc.

1282 Alturas Drive
 Moscow, ID 83843
 (208) 883-2839
 FAX 882-9246
 moscow@anateklabs.com

504 E. Sprague Ste. D
 Spokane, WA 99202
 (509) 838-3999
 FAX 838-4433
 spokane@anateklabs.com

www.anateklabs.com

Lead Analysis Report

Lab Sample #	Sample Location	Collection Date / Time	Analyte	Result	Method	Analysis Date	Analyst	Qualifier
161014024-001	161012H5 / RHS - SOCCER FIELD	10/12/2016 9:00 AM	Lead	ND	EPA 200.8	10/31/2016	HSW	
161014024-002	161012H6 / RHS - BASEBALL WEST	10/12/2016 9:05 AM	Lead	0.00592	EPA 200.8	10/31/2016	HSW	
161014024-003	161012H7 / RHS - BASEBALL EAST	10/12/2016 9:10 AM	Lead	0.00107	EPA 200.8	10/31/2016	HSW	
161014024-004	161012H8 / RHS - FOOTBALL FIELD	10/12/2016 9:15 AM	Lead	0.00207	EPA 200.8	10/31/2016	HSW	
161014024-005	161012H9 / RHS - SOFTBALL WEST	10/12/2016 9:20 AM	Lead	0.00334	EPA 200.8	10/31/2016	HSW	
161014024-006	161012H10 / RHS - SOFTBALL EAST	10/12/2016 9:20 AM	Lead	0.0116	EPA 200.8	10/31/2016	HSW	

MCL (Maximum Contaminant Level) for Lead is 0.020 mg/L.

MDL (Method Detection Limit) is 0.001 mg/L for Lead.

ND = Analyte Not Detected

All results in mg/L unless otherwise noted.


This report shall not be reproduced except in full, without the written approval of the laboratory.

The results reported relate only to the samples indicated.

Soil/solid results are reported on a dry-weight basis unless otherwise noted.

TABLE ROCK ANALYTICAL LAB
 MORROW COUNTY SCHOOL DIST.
 PO BOX 100
 HEPPNER, OR 97836

Authorized Signature


 Todd Taruscio, Lab Manager

Comments: BOARDMAN

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C596
 Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

LAB FEDERAL ID#:		ID00013
DATE RECEIVED:	10/14/2016	DATE REPORTED BY LAB: 11/3/2016
COMPLIANCE SAMPLE:	YES	REPLACEMENT SAMPLE: NO
SAMPLE TYPE:		
PWS #:	PWS NAME: MORROW COUNTY SCHOOL DIST.	
CONTACT NAME: TABLE ROCK ANALYTICAL LAB		CONTACT PHONE:



Anatek Labs, Inc.

1282 Alturas Drive
Moscow, ID 83843
(208) 883-2839
FAX 882-9246
moscow@anateklabs.com

504 E. Sprague Ste. D
Spokane, WA 99202
(509) 838-3999
FAX 838-4433
spokane@anateklabs.com

www.anateklabs.com

Lead Analysis Report

Lab Sample #	Sample Location	Collection Date / Time	Analyte	Result	Method	Analysis Date	Analyst	Qualifier
161014022-001	161012H11 / HIS - BASEBALL DRINKING	10/12/2016 10:00 AM	Lead	ND	EPA 200.8	10/31/2016	HSW	
161014022-002	161012H12 / HIS - BASEBALL DUGOUT	10/12/2016 10:00 AM	Lead	ND	EPA 200.8	10/31/2016	HSW	
161014022-003	161012H13 / HIS - SOFTBALL SPIKET	10/12/2016 10:05 AM	Lead	0.00622	EPA 200.8	10/31/2016	HSW	
161014022-004	161012H14 / ACH - PLAYGROUND FOUNT.	10/12/2016 10:20 AM	Lead	ND	EPA 200.8	10/31/2016	HSW	

MCL (Maximum Contaminant Level) for Lead is 0.020 mg/L.

MDL (Method Detection Limit) is 0.001 mg/L for Lead.

ND = Analyte Not Detected

All results in mg/L unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The results reported relate only to the samples indicated.

Soil/solid results are reported on a dry-weight basis unless otherwise noted.

TABLE ROCK ANALYTICAL LAB
MORROW COUNTY SCHOOL DIST.
PO BOX 100
HEPPNER, OR 97836

Authorized Signature

Todd Taruscio, Lab Manager

Comments: IRRIGON

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C505
Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871699